

Manufacturer	Type	Stakeholder Comment
Actaris/Schlum/Sangamo/Itron	ACE 1000 SMO	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	KBA	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	KBB	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	KBC	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	KBD	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	S200.13	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.16	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.28	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.30	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.31	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.32	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.33	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.38	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.4	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.7	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S204.7	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S210	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S220	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.12	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.13	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.14	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.15	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.2	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.3	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S301.1	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S301.6	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S301.9	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S304	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.1	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.10	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.11	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.2	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.4	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.5	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.50	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.51	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.9	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S309.1	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S309.2	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S309.3	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S309.5	Meter requires changing, unless "H" or "h" appears in meter type
AMPY/L+G	5056	May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5077	5077A - 'May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5162	5162E & 5162K - 'May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5192	5192A - 'May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5184	May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5196	5196A & 5196D - 'May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5209	Meter requires changing
AMPY/L+G	5219	5219J - May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5224E	May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5235	5235A - May show 'rEd' (reverse Energy detected) but readings are accurate
AMPY/L+G	5235***	5235D-N - May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5246C*-	May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5258*-	May show 'rEd' (reverse Energy detected), but readings are accurate
ARON	el	Certification expired - meter requires changing
ARON	G13	Certification expired - meter requires changing
ARON	G13P	Certification expired - meter requires changing
ARON	G23	Certification expired - meter requires changing
ARON	G23P	Certification expired - meter requires changing
ARON	G24	Certification expired - meter requires changing
ARON	G24P	Certification expired - meter requires changing
ARON	G33	Certification expired - meter requires changing
ARON	G33P	Certification expired - meter requires changing
ARON	G34	Certification expired - meter requires changing
ARON	G34P	Certification expired - meter requires changing
ARON	GM13	Certification expired - meter requires changing
ARON	GM13P	Certification expired - meter requires changing
ARON	GM23	Certification expired - meter requires changing
ARON	GM23P	Certification expired - meter requires changing
ARON	GM24	Certification expired - meter requires changing
ARON	GM24P	Certification expired - meter requires changing
ARON	GM33	Certification expired - meter requires changing
ARON	GM33P	Certification expired - meter requires changing
ARON	GM34	Certification expired - meter requires changing
ARON	GM34P	Certification expired - meter requires changing
ARON	GTM13	Certification expired - meter requires changing
ARON	GTM13P	Certification expired - meter requires changing

Manufacturer	Type	Stakeholder Comment
Horstmann/Secure Controls	NU077-2	'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	J2, K2 and variants	K222 - 'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	K1	K122 - 'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	S1*****	S111 - 'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	Series S	S111 & S123 - 'rEd' (reverse Energy detected), but readings are accurate
Iskra	ME162	Programmable meter which may differ, if configured as 'energy measurement type 4' then they will not increment readings correctly. The energy measurement type character at procurement is the tenth digit in the part number (shown on face-plate) not counting hyphens.
Metropolitan Vickers & AEI	NF5	Meter requires changing
Metropolitan Vickers & AEI	NQ	Meter requires changing
Siemens/L+G/FML/Ferranti	FMmP	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	FMmP2	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	HF3d	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	CL7	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL7d	Meter requires changing, unless "H" or "h" appears in meter type, CLhd
Siemens/L+G/FML/Ferranti	CH1	Meter requires changing
Siemens/L+G/FML/Ferranti	CH1d	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	DF3	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	DF3d	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	HF3	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	CL17	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL17d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CF6	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	YL1	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL1d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL11	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL11d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL11dm	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL27	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL27d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	FNN2	Meter requires changing
Siemens/L+G/FML/Ferranti	FNN2Q	Meter requires changing
Siemens/L+G/FML/Ferranti	CL27.1	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL27.1d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL11	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL11.5	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL11.5d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL11d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL27.2	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL27.2d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	F2Q-100	Meter requires changing
Siemens/L+G/FML/Ferranti	VL122	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL122d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL123	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL123d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL124	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL124d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL125	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL125dm	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL120	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL120dm	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL121	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL121d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL127	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL127d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100L	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100L-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	CL147	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL147d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100I	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100I-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-50B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-11B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100L	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-500	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-11B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-500C	Meter requires changing, unless "-9" appears in meter type

Manufacturer	Type	Stakeholder Comment
Siemens/L+G/FML/Ferranti	F2K-500C-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-500C-9	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100L-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100L	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100L-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10BL	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10BL-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11BL	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11BL-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100I	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100I-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100I	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100I-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10BI	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10BI-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11BI	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11BI-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-11B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-11B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-11BL	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-11BL-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-10B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-10B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	CM147dk10	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	CM147k10	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	S2S-700A	Subject to checking - confirm with Meter Operator
Siemens/L+G/FML/Ferranti	S2S-600A	Meter requires changing
Siemens/L+G/FML/Ferranti	VL11101	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL11101	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	ZCB220K	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	S2S-601A	Meter requires changing
Siemens/L+G/FML/Ferranti	S2A-100	Programmable meter which may differ, but examples do not increment readings correctly
Siemens/L+G/FML/Ferranti	S2A-200	Programmable meter which may differ, but examples do not increment readings correctly
Siemens/L+G/FML/Ferranti	S2AS	S2AS-100 - Meter requires changing
Siemens/L+G/FML/Ferranti	ZCE 527	'rEd' (reverse Energy detected), but readings are accurate
Smith	AM	Meter requires changing
Smith	APM	Certification expired - meter requires changing
Smith	APNE	Certification expired - meter requires changing
Smith	APNEQ	Certification expired - meter requires changing
Smith	APJ	Certification expired - meter requires changing
Smith	APQ	Certification expired - meter requires changing
Segam	CX1000-3 CLK	Meter requires changing - adds export to import consumption