

Manufacturer	Type	Stakeholder Comment
Actaris/Schlum/Sangamo/Itron	ACE 6000 Type 661	
Actaris/Schlum/Sangamo/Itron	ACE 6000 Type 661	
Actaris/Schlum/Sangamo/Itron	ACE 1000 SMO	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	ACE 1000-282	
Actaris/Schlum/Sangamo/Itron	ACE 2000-292	
Actaris/Schlum/Sangamo/Itron	ACE 3000 Type 100/110	
Actaris/Schlum/Sangamo/Itron	ACE 4000 Type GT**	
Actaris/Schlum/Sangamo/Itron	ACE 5000	
Actaris/Schlum/Sangamo/Itron	ACE 6000 Typ 661	
Actaris/Schlum/Sangamo/Itron	ACE 6000 Type 665	
Actaris/Schlum/Sangamo/Itron	ACE 9000 KBD2E	
Actaris/Schlum/Sangamo/Itron	C114N1R1	
Actaris/Schlum/Sangamo/Itron	CBA	
Actaris/Schlum/Sangamo/Itron	FX221	
Actaris/Schlum/Sangamo/Itron	FX221	
Actaris/Schlum/Sangamo/Itron	H10	
Actaris/Schlum/Sangamo/Itron	HMT	
Actaris/Schlum/Sangamo/Itron	KBA	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	KBB	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	KBC	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	KBD	Green fraud light will illuminate, but readings are accurate
Actaris/Schlum/Sangamo/Itron	KXB	
Actaris/Schlum/Sangamo/Itron	MBA	
Actaris/Schlum/Sangamo/Itron	MC3	
Actaris/Schlum/Sangamo/Itron	MC3	
Actaris/Schlum/Sangamo/Itron	MTA	
Actaris/Schlum/Sangamo/Itron	MTB	
Actaris/Schlum/Sangamo/Itron	MTN	
Actaris/Schlum/Sangamo/Itron	Nikolas - ACE 3000	
Actaris/Schlum/Sangamo/Itron	P5A	
Actaris/Schlum/Sangamo/Itron	P5A	
Actaris/Schlum/Sangamo/Itron	P6A	
Actaris/Schlum/Sangamo/Itron	PIA	
Actaris/Schlum/Sangamo/Itron	PIA	
Actaris/Schlum/Sangamo/Itron	PIB / PLB	
Actaris/Schlum/Sangamo/Itron	PIB / PLB	
Actaris/Schlum/Sangamo/Itron	PPA-1	
Actaris/Schlum/Sangamo/Itron	PPA-2	
Actaris/Schlum/Sangamo/Itron	PPB	
Actaris/Schlum/Sangamo/Itron	PXA	
Actaris/Schlum/Sangamo/Itron	PXA	
Actaris/Schlum/Sangamo/Itron	PXA/I	
Actaris/Schlum/Sangamo/Itron	S2.20 or M2X	
Actaris/Schlum/Sangamo/Itron	S200.13	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.16	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.28	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.30	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.31	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.32	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.33	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.38	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.4	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S200.7	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S203.1	
Actaris/Schlum/Sangamo/Itron	S204.16	
Actaris/Schlum/Sangamo/Itron	S204.7	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S206.16	
Actaris/Schlum/Sangamo/Itron	S206.7	
Actaris/Schlum/Sangamo/Itron	S207.2	
Actaris/Schlum/Sangamo/Itron	S207.4	
Actaris/Schlum/Sangamo/Itron	S210	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S220	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.12	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.13	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.14	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.15	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.2	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S29.3	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S300.1	
Actaris/Schlum/Sangamo/Itron	S300.3	
Actaris/Schlum/Sangamo/Itron	S301.1	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S301.6	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S301.9	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S304	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.1	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.10	Certification expired - meter requires changing

Manufacturer	Type	Stakeholder Comment
Actaris/Schlum/Sangamo/Itron	S304.11	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.2	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.4	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.5	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.50	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.51	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S304.60	
Actaris/Schlum/Sangamo/Itron	S304.61	
Actaris/Schlum/Sangamo/Itron	S304.9	Certification expired - meter requires changing
Actaris/Schlum/Sangamo/Itron	S309.1	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S309.2	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S309.3	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S309.5	Meter requires changing, unless "H" or "h" appears in meter type
Actaris/Schlum/Sangamo/Itron	S320.1	
Actaris/Schlum/Sangamo/Itron	S320.1	
Actaris/Schlum/Sangamo/Itron	S320.4	
Actaris/Schlum/Sangamo/Itron	S320.7	
Actaris/Schlum/Sangamo/Itron	S320.7	
Actaris/Schlum/Sangamo/Itron	S320.75	
Actaris/Schlum/Sangamo/Itron	S321.1	
Actaris/Schlum/Sangamo/Itron	S321.6	
Actaris/Schlum/Sangamo/Itron	S321.9	
Actaris/Schlum/Sangamo/Itron	S322.12	
Actaris/Schlum/Sangamo/Itron	S322.15	
Actaris/Schlum/Sangamo/Itron	S322.6	
Actaris/Schlum/Sangamo/Itron	S322.9	
Actaris/Schlum/Sangamo/Itron	S323.1	
Actaris/Schlum/Sangamo/Itron	S323.12	
Actaris/Schlum/Sangamo/Itron	S323.6	
Actaris/Schlum/Sangamo/Itron	S323.9	
Actaris/Schlum/Sangamo/Itron	S325.3	
Actaris/Schlum/Sangamo/Itron	S326.1	
Actaris/Schlum/Sangamo/Itron	S326.6	
Actaris/Schlum/Sangamo/Itron	S326.9	
Actaris/Schlum/Sangamo/Itron	S327.3	
Actaris/Schlum/Sangamo/Itron	S327.6	
Actaris/Schlum/Sangamo/Itron	S330.1	
Actaris/Schlum/Sangamo/Itron	SBB	
Actaris/Schlum/Sangamo/Itron	SM1	
Actaris/Schlum/Sangamo/Itron	SPA01	
Actaris/Schlum/Sangamo/Itron	SPA02	
Actaris/Schlum/Sangamo/Itron	SPA03	
Actaris/Schlum/Sangamo/Itron	SPA11	
Actaris/Schlum/Sangamo/Itron	SPA13	
Actaris/Schlum/Sangamo/Itron	SPB	
Actaris/Schlum/Sangamo/Itron	SPB15	
Actaris/Schlum/Sangamo/Itron	SPC	
Actaris/Schlum/Sangamo/Itron	SPX	
Actaris/Schlum/Sangamo/Itron	ST-Q220	
Actaris/Schlum/Sangamo/Itron	ST-Q230	
Actaris/Schlum/Sangamo/Itron	T2C114N1R1	
Actaris/Schlum/Sangamo/Itron	TRA	
Actaris/Schlum/Sangamo/Itron	TRX	
AMPY/L+G	5028A	
AMPY/L+G	5054C	
AMPY/L+G	5056	May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5028L	
AMPY/L+G	5054	
AMPY/L+G	5071	
AMPY/L+G	5077	5077A - 'May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5057	
AMPY/L+G	5162	5162E & 5162K - 'May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5165	
AMPY/L+G	5178A	
AMPY/L+G	5188	
AMPY/L+G	5193	
AMPY/L+G	5194	
AMPY/L+G	5192	5192A - 'May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5184	May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5196	5196A & 5196D - 'May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5207	
AMPY/L+G	5209	Meter requires changing
AMPY/L+G	5226	
AMPY/L+G	5232A	
AMPY/L+G	5219	5219J - May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5224E	May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5235	5235A - May show 'rEd' (reverse Energy detected) but readings are accurate

Manufacturer	Type	Stakeholder Comment
AMPY/L+G	5235***	5235D-N - May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5164	
AMPY/L+G	5246C-*	May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5258*.*	May show 'rEd' (reverse Energy detected), but readings are accurate
AMPY/L+G	5254E & 5254F	
AMPY/L+G	EM1200	
ARON	eI	Certification expired - meter requires changing
ARON	G13	Certification expired - meter requires changing
ARON	G13P	Certification expired - meter requires changing
ARON	G23	Certification expired - meter requires changing
ARON	G23P	Certification expired - meter requires changing
ARON	G24	Certification expired - meter requires changing
ARON	G24P	Certification expired - meter requires changing
ARON	G33	Certification expired - meter requires changing
ARON	G33P	Certification expired - meter requires changing
ARON	G34	Certification expired - meter requires changing
ARON	G34P	Certification expired - meter requires changing
ARON	GM13	Certification expired - meter requires changing
ARON	GM13P	Certification expired - meter requires changing
ARON	GM23	Certification expired - meter requires changing
ARON	GM23P	Certification expired - meter requires changing
ARON	GM24	Certification expired - meter requires changing
ARON	GM24P	Certification expired - meter requires changing
ARON	GM33	Certification expired - meter requires changing
ARON	GM33P	Certification expired - meter requires changing
ARON	GM34	Certification expired - meter requires changing
ARON	GM34P	Certification expired - meter requires changing
ARON	GTM13	Certification expired - meter requires changing
ARON	GTM13P	Certification expired - meter requires changing
ARON	GTM23	Certification expired - meter requires changing
ARON	GTM23P	Certification expired - meter requires changing
ARON	GTM24	Certification expired - meter requires changing
ARON	GTM24P	Certification expired - meter requires changing
ARON	GTM33	Certification expired - meter requires changing
ARON	GTM33P	Certification expired - meter requires changing
ARON	GTM34	Certification expired - meter requires changing
ARON	GTM34P	Certification expired - meter requires changing
ARON	eN	Certification expired - meter requires changing
Autometers Systems Ltd	IC 200-IM-R	
CEWE	CE	
CEWE	CE	
CEWE	CE	
CEWE	CE	
CEWE	2***, 3***, 4***	
CEWE	Prometer-R	
CEWE	Prometer-W	
Chamberlain & Hookham	K	Meter requires changing
Chamberlain & Hookham	PT2	Certification expired - meter requires changing
Chamberlain & Hookham	PT2D	Certification expired - meter requires changing
Chamberlain & Hookham	PT4	
Chamberlain & Hookham	PT4D	Certification expired - meter requires changing
Dennis Ferranti	TM3c	Meter requires changing
Dennis Ferranti	B1V7	
Echelon	EM-1021 83861-1****	
Echelon	EM-1023 83321-3****	
EDMI	Mk 10E	
	1E** **** ** ** **	
	**** **	
EDMI	Atlas Mk 10 - 2	
EDMI	Atlas Mk 10 - 2(CT)	
EDMI	Atlas Mk 10 - 1	
EDMI	Atlas Mk 10 - 1(CT)	
EDMI Limited	Atlas Mk10-4-2000-10*3-1A1-15-A-****-***** and Atlas Mk 10*-2000-1010-1A1-15-AD2*0-***	
EDMI Limited	Atlas Mk10-4-2000-10*3-1C2-15-A****.***** and Atlas Mk 10*-2000-1010-1C2-15-AD2*0-***	
EDMI Limited	Mk 6E 2000-6E**_*****-***_***_***	
EI Sewedy	EM101-4	
EI Sewedy	EM341-4	
Elster Metering Systems Ltd	A 1700 PB2 & PB3	





Manufacturer	Type	Stakeholder Comment
Elster/ABB/GEC/EE	CM7	
Elster/ABB/GEC/EE	PM2***JK	
Elster/ABB/GEC/EE	PM3***JK	
Elster/ABB/GEC/EE	SC2B	
Elster/ABB/GEC/EE	T81	
Elster/ABB/GEC/EE	M81	
Elster/ABB/GEC/EE	C11B3	Meter requires changing, unless "H" or "h" appears in meter type
Elster/ABB/GEC/EE	C11B3C	Meter requires changing, unless "H" or "h" appears in meter type
Elster/ABB/GEC/EE	EP2	
Elster/ABB/GEC/EE	EP2J	
Elster/ABB/GEC/EE	EP3	
Elster/ABB/GEC/EE	EP3J	
Elster/ABB/GEC/EE	PM3 (CT operated)	
Elster/ABB/GEC/EE	PM2 (CT operated)	
Elster/ABB/GEC/EE	PM3	
Elster/ABB/GEC/EE	PM2	
Elster/ABB/GEC/EE	J11B	Meter requires changing, unless "H" or "h" appears in meter type
Elster/ABB/GEC/EE	PB3	
Elster/ABB/GEC/EE	J11D	Meter requires changing, unless "H" or "h" appears in meter type
Elster/ABB/GEC/EE	PB3	
Elster/ABB/GEC/EE	PB2	
Elster/ABB/GEC/EE	PB2	
Elster/ABB/GEC/EE	A120 & A140 (SB1 & SD1)	
Elster/ABB/GEC/EE	EI3S	
Elster/ABB/GEC/EE	A101	
Elster/ABB/GEC/EE	E111	
Elster/ABB/GEC/EE	E211	
Elster/ABB/GEC/EE	A1100	
Elster/ABB/GEC/EE	A100C	
Elster/ABB/GEC/EE	A200	
Elster/ABB/GEC/EE	A1120 & A1140	
GANZ	GE24	
GANZ	GH42	
Hangzhou Autometers Ltd	S12	
Horstmann/Secure Controls	NU 070	
Horstmann/Secure Controls	NU 070 2	
Horstmann/Secure Controls	NU 076	
Horstmann/Secure Controls	NU 076-2	
Horstmann/Secure Controls	NU077-1	'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	NU077-2	'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	NU098	
Horstmann/Secure Controls	L100A00 & variants	
Horstmann/Secure Controls	J2, K2 and variants	K222 - 'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	K1	K122 - 'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	M1*****	
Horstmann/Secure Controls	S1*****	S111 - 'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	Series S	S111 & S123 - 'rEd' (reverse Energy detected), but readings are accurate
Horstmann/Secure Controls	A115A** and A222A**	
Horstmann/Secure Controls	MAINSCOM	
IDS Limited	Mainstar	
Iskra	E89AT2	
Iskra	E89E2	
Iskra	E89ATD2	
Iskra	E89ED2	
Iskra	T31AT2	
Iskra	T31ATD2	
Iskra	T37E2	
Iskra	T37ED2	
Iskra	E96E2	
Iskra	TE33	
Iskra	TE44	
Iskra	ME 100, 150 & 200	
Iskra	ME 22 P	
Iskra	MT3	
Iskra	MT3**	
Iskra	T36 1C2	
Iskra	ME160	
Iskra	MT401	
Iskra	ME161	
Iskra	MT420	
Iskra	MT423	
Iskra	MT171	
Iskra	ME162	Programmable meter which may differ, if configured as 'energy measurement type 4' then they will not increment readings correctly. The energy measurement type character at procurement is the tenth digit in the part number (shown on face-plate) not counting hyphens.
Iskra	ME351	

Manufacturer	Type	Stakeholder Comment
Iskra	MT351	
Iskra	ME22P	
Iskra	MT37*-**A*****	
Iskra	MT372 & MT375	
Iskra	ME371 & ME 372	
Janz-Contadores de Energia	B1**	
Janz-Contadores de Energia	C2**	
JSC (Krasnodarsky Zip)/Jugmera	EE 3000 M	
Kamstrup A/S	685-351-**-00-050	
Kamstrup A/S	686-162	
Kamstrup A/S	685-38*-OK-50	
Landis & Gyr Limited	Z*Q20*C.*r****f *	
Landis & Gyr Limited	Z*D4**CT**.*****S2	
Metropolitan Vickers & AEI	NF5	Meter requires changing
Metropolitan Vickers & AEI	NQ	Meter requires changing
Metropolitan Vickers & AEI	NQ/M	
NAMS/Nisko	NMM - ES	
NAMS/Nisko	AK-2000	
NAMS/Nisko	ES-2000P	
NAMS/Nisko	AK-2000P	
NAMS/Nisko	AK2000C	
er Measurement Ltd (Schneider Ele	73**	
er Measurement Ltd (Schneider Ele	ION P7550****0*5***.	
er Measurement Ltd (Schneider Ele	ION P7650****0*5****	
er Measurement Ltd (Schneider Ele	ION *8800****0B5*****	
er Measurement Ltd (Schneider Ele	ION *7550****0*5*****	
er Measurement Ltd (Schneider Ele	ION *7650****0*5*****	
PRI Ltd/Secure Meters (UK) Ltd	CALMU C3D	
PRI Ltd/Secure Meters (UK) Ltd	CALMU C3T	
PRI Ltd/Secure Meters (UK) Ltd	CALMU C3TV	
PRI Ltd/Secure Meters (UK) Ltd	C3TV	
PRI Ltd/Secure Meters (UK) Ltd	C3V+	
PRI Ltd/Secure Meters (UK) Ltd	C3T+	
PRI Ltd/Secure Meters (UK) Ltd	CALMU3 C3T+	
PRI Ltd/Secure Meters (UK) Ltd	CALMU3 C3V+	
PRI Ltd/Secure Meters (UK) Ltd	C3D+	
PRI Ltd/Secure Meters (UK) Ltd	S3DXP410	
PRI Ltd/Secure Meters (UK) Ltd	P3M	
PRI Ltd/Secure Meters (UK) Ltd	P3T***	
PRI Ltd/Secure Meters (UK) Ltd	S3D410	
PRI Ltd/Secure Meters (UK) Ltd	P3VA11	
PRI Ltd/Secure Meters (UK) Ltd	P3V	
PRI Ltd/Secure Meters (UK) Ltd	R3V025-100	
PRI Ltd/Secure Meters (UK) Ltd	R3V021-100	
PRI Ltd/Secure Meters (UK) Ltd	R3M025-100	
PRI Ltd/Secure Meters (UK) Ltd	R3M021-100	
PRI Ltd/Secure Meters (UK) Ltd	LIBERTY 3E E1D104-	
	100 E1D204-100	
PRI Ltd/Secure Meters (UK) Ltd	LIBERTY 3E E1D*04-	
	*00/M	
PRI Ltd/Secure Meters (UK) Ltd	LIBERTY 3P	
	E3PD** ***	
PRI Ltd/Secure Meters (UK) Ltd	LIBERTY 3P	
	E3PD** ***/M	
PRI Ltd/Secure Meters (UK) Ltd	LIBERTY 1E E1D*04-	
	***	
PRI Ltd/Secure Meters (UK) Ltd	LIBERTY 1E E1D***-	
	***M	
PRI Ltd/Secure Meters (UK) Ltd	E1C***-11i	
PRI Ltd/Secure Meters (UK) Ltd	Sprint XP	
PRI Ltd/Secure Meters (UK) Ltd	Premier	
	P3*****N*M	
PRI Ltd/Secure Meters (UK) Ltd	Premier	
	P3*****N5M	
Sanneng Meter Systems Limited	DDS43	
Sanneng Meter Systems Limited	DTS43	
Secure Meters Ltd	E1D	
Shanghai Electricity Meter	FD 95	
Siemens/L+G/FML/Ferranti	FM	
Siemens/L+G/FML/Ferranti	FMm	
Siemens/L+G/FML/Ferranti	FMP	
Siemens/L+G/FML/Ferranti	FMmP	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	FMmP2	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	FMP2	
Siemens/L+G/FML/Ferranti	FMmY	
Siemens/L+G/FML/Ferranti	FMmYT	
Siemens/L+G/FML/Ferranti	FMY	



Manufacturer	Type	Stakeholder Comment
Siemens/L+G/FML/Ferranti	FMmX	
Siemens/L+G/FML/Ferranti	FMmXT	
Siemens/L+G/FML/Ferranti	FMX	
Siemens/L+G/FML/Ferranti	MF3	
Siemens/L+G/FML/Ferranti	MF3d	
Siemens/L+G/FML/Ferranti	FMXMD	
Siemens/L+G/FML/Ferranti	HF3d	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	FMMD	
Siemens/L+G/FML/Ferranti	FMmMD	
Siemens/L+G/FML/Ferranti	FMT	
Siemens/L+G/FML/Ferranti	FMXT	
Siemens/L+G/FML/Ferranti	CL7	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL7d	Meter requires changing, unless "H" or "h" appears in meter type, CLhd
Siemens/L+G/FML/Ferranti	CH1	<b>Meter requires changing</b>
Siemens/L+G/FML/Ferranti	CH1d	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	DF3	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	DF3d	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	HF3	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	MH1	
Siemens/L+G/FML/Ferranti	MH1dm	
Siemens/L+G/FML/Ferranti	FMXa	
Siemens/L+G/FML/Ferranti	CL17	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL17d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CF6	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	DF34	
Siemens/L+G/FML/Ferranti	DF34dm	
Siemens/L+G/FML/Ferranti	FF34	
Siemens/L+G/FML/Ferranti	HF34	
Siemens/L+G/FML/Ferranti	HF34dm	
Siemens/L+G/FML/Ferranti	MF34	
Siemens/L+G/FML/Ferranti	MF34dm	
Siemens/L+G/FML/Ferranti	FMXaT	
Siemens/L+G/FML/Ferranti	YL1	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL1d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	FN12	
Siemens/L+G/FML/Ferranti	FNE12	
Siemens/L+G/FML/Ferranti	FN12Q	
Siemens/L+G/FML/Ferranti	FNE12Q	
Siemens/L+G/FML/Ferranti	YL11	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL11d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL11dm	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL27	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL27d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	FN12P	
Siemens/L+G/FML/Ferranti	FNE12P	
Siemens/L+G/FML/Ferranti	FN12PF	
Siemens/L+G/FML/Ferranti	FNE12PF	
Siemens/L+G/FML/Ferranti	FN34	
Siemens/L+G/FML/Ferranti	FN34QR2	
Siemens/L+G/FML/Ferranti	FNE34	
Siemens/L+G/FML/Ferranti	FN33	
Siemens/L+G/FML/Ferranti	FN33Q	
Siemens/L+G/FML/Ferranti	FNE33	
Siemens/L+G/FML/Ferranti	FNE33Q	
Siemens/L+G/FML/Ferranti	FN12QP	
Siemens/L+G/FML/Ferranti	FNE12QP	
Siemens/L+G/FML/Ferranti	FN12QPF	
Siemens/L+G/FML/Ferranti	FNE12QPF	
Siemens/L+G/FML/Ferranti	FNA34R2	
Siemens/L+G/FML/Ferranti	FNEA33	
Siemens/L+G/FML/Ferranti	FNEA33Q	
Siemens/L+G/FML/Ferranti	FNEA34	
Siemens/L+G/FML/Ferranti	FN34Q	
Siemens/L+G/FML/Ferranti	FNA34	
Siemens/L+G/FML/Ferranti	FNA34Q	
Siemens/L+G/FML/Ferranti	FNE34Q	
Siemens/L+G/FML/Ferranti	FNEA34Q	
Siemens/L+G/FML/Ferranti	CL28	
Siemens/L+G/FML/Ferranti	CL28d	
Siemens/L+G/FML/Ferranti	FMQ	
Siemens/L+G/FML/Ferranti	FN12R2	
Siemens/L+G/FML/Ferranti	FNE12QR2	
Siemens/L+G/FML/Ferranti	FNE12R2	
Siemens/L+G/FML/Ferranti	FN34R2	
Siemens/L+G/FML/Ferranti	FNA34QR2	
Siemens/L+G/FML/Ferranti	FNE34QR2	
Siemens/L+G/FML/Ferranti	FNE34R2	



Manufacturer	Type	Stakeholder Comment
Siemens/L+G/FML/Ferranti	FNEA34QR2	
Siemens/L+G/FML/Ferranti	FNEA34R2	
Siemens/L+G/FML/Ferranti	FN33QR2	
Siemens/L+G/FML/Ferranti	FN33R2	
Siemens/L+G/FML/Ferranti	FNE33QR2	
Siemens/L+G/FML/Ferranti	FNE33R2	
Siemens/L+G/FML/Ferranti	FN12D	
Siemens/L+G/FML/Ferranti	FNE12D	
Siemens/L+G/FML/Ferranti	FN34D	
Siemens/L+G/FML/Ferranti	FN34QD	
Siemens/L+G/FML/Ferranti	FNE33D	
Siemens/L+G/FML/Ferranti	FNE33QD	
Siemens/L+G/FML/Ferranti	FNE34D	
Siemens/L+G/FML/Ferranti	FNE34QD	
Siemens/L+G/FML/Ferranti	FNA33D	
Siemens/L+G/FML/Ferranti	FNA34D	
Siemens/L+G/FML/Ferranti	FNEA33D	
Siemens/L+G/FML/Ferranti	FNEA33QD	
Siemens/L+G/FML/Ferranti	FNEA34D	
Siemens/L+G/FML/Ferranti	FNEA34QD	
Siemens/L+G/FML/Ferranti	FNN2	Meter requires changing
Siemens/L+G/FML/Ferranti	FNN2Q	Meter requires changing
Siemens/L+G/FML/Ferranti	CL27.1	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL27.1d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	FN12QD	
Siemens/L+G/FML/Ferranti	FNE12QD	
Siemens/L+G/FML/Ferranti	VL11	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL11.5	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL11.5d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL11d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	FNA33	
Siemens/L+G/FML/Ferranti	FNA33Q	
Siemens/L+G/FML/Ferranti	FNA33QR2	
Siemens/L+G/FML/Ferranti	FNA33R2	
Siemens/L+G/FML/Ferranti	FNEA33QR2	
Siemens/L+G/FML/Ferranti	FNEA33R2	
Siemens/L+G/FML/Ferranti	FNA34QD	
Siemens/L+G/FML/Ferranti	CL27.2	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL27.2d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	FNN2QD	
Siemens/L+G/FML/Ferranti	F2Q-100	Meter requires changing
Siemens/L+G/FML/Ferranti	F2Q-11B	
Siemens/L+G/FML/Ferranti	FPQ-102	
Siemens/L+G/FML/Ferranti	FNAB34	
Siemens/L+G/FML/Ferranti	FNAB34Q	
Siemens/L+G/FML/Ferranti	FNAB34QR2	
Siemens/L+G/FML/Ferranti	FNAB34R2	
Siemens/L+G/FML/Ferranti	VL122	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL122d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL123	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL123d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL124	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL124d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL125	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	VL125dm	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL120	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL120dm	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL121	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL121d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	FNAB33	
Siemens/L+G/FML/Ferranti	FNAB33Q	
Siemens/L+G/FML/Ferranti	FNAB33QR2	
Siemens/L+G/FML/Ferranti	FNAB33R2	
Siemens/L+G/FML/Ferranti	FNAB33D	
Siemens/L+G/FML/Ferranti	FNAB34D	
Siemens/L+G/FML/Ferranti	FNAB34QD	
Siemens/L+G/FML/Ferranti	FN33D	
Siemens/L+G/FML/Ferranti	FN34DR2	
Siemens/L+G/FML/Ferranti	FMXMDR2	
Siemens/L+G/FML/Ferranti	FMYMDR2	
Siemens/L+G/FML/Ferranti	F2Q-10W	
Siemens/L+G/FML/Ferranti	F2Q-10D	
Siemens/L+G/FML/Ferranti	F2Q-11D	
Siemens/L+G/FML/Ferranti	CL127	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL127d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100-2	Meter requires changing, unless "-9" appears in meter type

Manufacturer	Type	Stakeholder Comment
Siemens/L+G/FML/Ferranti	F2K-100L	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100L-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	CL147	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	CL147d	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100I	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-100I-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	FNN2QC	
Siemens/L+G/FML/Ferranti	F4K-100	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-50B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-11B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100L	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-500	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-11B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-500C	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-500C-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F2K-500C-9	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100L-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100L	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100L-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10BL	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10BL-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11BL	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11BL-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100I	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-100I-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100I	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-100I-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10BI	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-10BI-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11BI	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F4K-11BI-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-11B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-11B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-11BL	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-11BL-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-10B	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	F3K-10B-2	Meter requires changing, unless "-9" appears in meter type
Siemens/L+G/FML/Ferranti	CM147	
Siemens/L+G/FML/Ferranti	CM147d	
Siemens/L+G/FML/Ferranti	F2K-500D	
Siemens/L+G/FML/Ferranti	CM147dk10	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	CM147k10	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	F2K-500D-2	
Siemens/L+G/FML/Ferranti	F2K-500D-9	
Siemens/L+G/FML/Ferranti	S2S-500A1	
Siemens/L+G/FML/Ferranti	S2S-500A2	
Siemens/L+G/FML/Ferranti	ZCB120	
Siemens/L+G/FML/Ferranti	ZCB120d	
Siemens/L+G/FML/Ferranti	S2S-700A	Subject to checking - confirm with Meter Operator
Siemens/L+G/FML/Ferranti	S2S-600A	Meter requires changing
Siemens/L+G/FML/Ferranti	ZCB127	
Siemens/L+G/FML/Ferranti	ZCB127	
Siemens/L+G/FML/Ferranti	S4S-11B	
Siemens/L+G/FML/Ferranti	ZMB127	
Siemens/L+G/FML/Ferranti	ZMB127d	
Siemens/L+G/FML/Ferranti	ZFA405	
Siemens/L+G/FML/Ferranti	ZMA405	
Siemens/L+G/FML/Ferranti	ZCA405	
Siemens/L+G/FML/Ferranti	S4S 100	
Siemens/L+G/FML/Ferranti	FF10	
Siemens/L+G/FML/Ferranti	MF10	
Siemens/L+G/FML/Ferranti	VL11101	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	YL11101	Meter requires changing, unless "H" or "h" appears in meter type
Siemens/L+G/FML/Ferranti	ZCB220K	Certification expired - meter requires changing
Siemens/L+G/FML/Ferranti	S2S-601A	Meter requires changing
Siemens/L+G/FML/Ferranti	ML240xtf3	
Siemens/L+G/FML/Ferranti	S2S-720A	
Siemens/L+G/FML/Ferranti	S2S-730A	
Siemens/L+G/FML/Ferranti	S2A-100	Programmable meter which may differ, but examples do not increment readings correctly
Siemens/L+G/FML/Ferranti	S2A-200	Programmable meter which may differ, but examples do not increment readings correctly

Manufacturer	Type	Stakeholder Comment
Siemens/L+G/FML/Ferranti	F2K-100H-9	
Siemens/L+G/FML/Ferranti	ZMB120K	
Siemens/L+G/FML/Ferranti	7EC49	
Siemens/L+G/FML/Ferranti	ZCB221k	
Siemens/L+G/FML/Ferranti	Q4N	
Siemens/L+G/FML/Ferranti	S2AS	S2AS-100 - Meter requires changing
Siemens/L+G/FML/Ferranti	ZMB120k	
Siemens/L+G/FML/Ferranti	S2BS	
Siemens/L+G/FML/Ferranti	S2BS	
Siemens/L+G/FML/Ferranti	S2AT	
Siemens/L+G/FML/Ferranti	ZMD120AM	
Siemens/L+G/FML/Ferranti	S2AM-100	
Siemens/L+G/FML/Ferranti	ZCE127	
Siemens/L+G/FML/Ferranti	ZMD120AS	
Siemens/L+G/FML/Ferranti	ZCE129ACd	
Siemens/L+G/FML/Ferranti	ZCE129ACe	
Siemens/L+G/FML/Ferranti	CM100	
Siemens/L+G/FML/Ferranti	MM2000	
Siemens/L+G/FML/Ferranti	ZCE 527	'rEd' (reverse Energy detected), but readings are accurate
Smith	AM	Meter requires changing
Smith	APM	Certification expired - meter requires changing
Smith	APNE	Certification expired - meter requires changing
Smith	APNEQ	Certification expired - meter requires changing
Smith	APJ	Certification expired - meter requires changing
Smith	APQ	Certification expired - meter requires changing
Zaptronix	ZAP01	
Segam	CX1000-3 CLK	Meter requires changing - adds export to import consumption